


NOTES:

1. GAS/DIESEL USE
2. ENVIROLASTIC 940 DTM POLYASPARTIC URETHANE COATING FOR HIGH PERFORMANCE FINISH (MEMCO GREY)
3. UL 2085 LABELED AND LISTED
4. 2 HOUR RATING TESTED TO SWRI 97-04 NFPA 30 A FIRE RESISTANT TANK
5. ENGINEERED HURRICANE TIE-DOWN
6. LEAD TIME IS DEPENDENT ON IMMEDIATE APPROVAL




LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN

#



STI
SwRI
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP		4/25/2019		MEMCO, INC	
MEMCO REP				 6,000 GALLON FIREGUARD DISPENSER SYSTEM <small>ABOVE-GROUND FUEL SYSTEMS</small>	
QUOTE #					
Customer Approval Signature				SIZE C	DWG NO
CUSTOMER REQUESTED COMPLETION DATE :				SCALE	REV
				SHEET 1 OF 5	

PARTS LIST		
ITEM	QTY	DESCRIPTION
1	1	6,000 GALLON FIREGUARD TANK MOUNTED ON SADDLES
2	1	18" MANWAY FOR EASY INNER TANK ACCESSIBILITY
3	2	8 IN NPT THREADED FLANGE
4	1	6 IN NPT THREADED FLANGE
5	5	4 IN NPT THREADED FLANGE
6	5	3" NPT THREADED FLANGE (CONCRETE PORT)
7	1	3 IN NPT THREADED FLANGE
8	2	2 IN NPT THREADED FLANGE
9	2	LIFTING LUG
10	2	VENT EMERGENCY 8IN 8OZ./SQ.IN- MALE THREAD- w/O-RING
11	1	3" OVERFILL PREVENTION VALVE WITH DIFFUSER AND TEST MECHANISM
12	1	3" GROUND LEVEL FILL WITH DUST CAP AND ADAPTOR
13	1	918 CLOCK GAUGE WITH ALARM BOX AND STANDARD FLOAT
14	1	INTERSTITIAL LEAK GAUGE
15	1	3" UPDRAFT STACK W/3" 354 SLIP ON

PARTS LIST		
ITEM	QTY	DESCRIPTION
16	1	MONITORING CAP 2"
17	1	UL LISTED LOCKABLE 3'x4'2"x4" FILL BOX, CROSS BROKEN FOR EASY DRAINAGE, 2" STACK VENT AND 1/2" BALL VALVE
18	1	LADDER MOUNTED ON BOX TO ACCESS TOP OF THE TANK WITH HANDRAIL SYSTEM
19	1	FE PETRO 3/4 HP w/RISER, 88IN - 149IN (240V 1 PH)
20	1	2" SHEAR VALVE
21	1	VALVE BALL 2IN
22	1	2" ANTI-SIPHON VALVE
23	1	DISPENSER BENETT SINGLE PRODUCT 3711SNR-18-J-PSO
24	1	1/2" BRASS BALL VALVE
25	1	NEMA 7 EXPLOSION PROOF BOX FOR CBS SWITCH
26	1	BOX SINGLE PHASE CONTROL w/SWITCH & LOCKOUT 120V COIL (NOT SHOWN)
27	1	TANK DECAL KIT (NOT SHOWN)
28	1	TOUCH UP PAINT (NOT SHOWN & SHIPPED SEPARATELY)



SHELL THICKNESS: 1/4"
HEAD THICKNESS: 1/4"

STI
SwRI
UL

LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN

#

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY	AP	4/25/2019
MEMCO REP		
QUOTE #		
Customer Approval Signature		


MEMCO, INC

envirosafeTM

6,000 GALLON FIREGUARD DISPENSER SYSTEM

ABOVE-GROUND FUEL SYSTEMS


SIZE	DWG NO	REV
C		
SCALE	SHEET 2 OF 5	



LEAD TIMES BEGIN UPON RECEIPT OF SIGNED APPROVED DRAWING, WHICH MUST BE RETURNED BEFORE PRODUCTION CAN BEGIN #

STI
SwRI
UL

This document and all information and design thereon are the property of Envirosafe Fuel Systems. This document is confidential and must not be made public or copied without written authorization from Envirosafe and is subject to return upon demand. No use of this document or any design thereon is permitted except as is specifically authorized in writing by Envirosafe. Acceptance of possession of this document constitutes full agreement with the above conditions. All Rights Reserved. Memco, Inc

DRAWN BY AP	4/25/2019	MEMCO, INC	
MEMCO REP		 6,000 GALLON FIREGUARD DISPENSER SYSTEM <small>ABOVE-GROUND FUEL SYSTEMS</small>	
QUOTE #			
Customer Approval Signature		SIZE C	DWG NO
		SCALE	REV
		SHEET 3 OF 5	